

**Pine Forest HOA
PO Box 443
Winthrop, WA 98862**

**Consumer Confidence Report (CCR)
July 2, 2018**

Report written by: Brad Sawtell

Our Community Water System

Our water system is actually three separate systems with two well fields. Water is pressurized by gravity. During power outages, no water is pumped to the storage tanks, so it is advised to turn off any and all outdoor irrigation when the power is out. System 1 is known as the “South System” and systems 2 and 3 are known as the “North System”.

Systems 2 and 3 serve all of the water connections (homes) North of Summer Road. The water comes from the well field and pump house located at the South end of the hay field, which is South of Patterson Lake. Water is pumped uphill, filling two storage tanks (10,000 gallons each) and a Mid Station located on Umbrella Pine. The tanks (System 3) serve all homes downhill on Umbrella Pine, Rocky Top, Sugar Pine, Whitebark, Rodeo, (lower) Summer Road and N Blackjack. Water is also pumped from the Mid Station uphill, filling two storage (10k gallons ea.) tanks located on US Forest Service land just West of the upper parking area at the end of Nighthawk Ridge Road. These tanks (System 2) supply water to connections on Nighthawk Ridge and Summer Roads (down to Whitebark).

System 1 services all connections (homes) South of Summer Road. This system starts at a well field and pump house near the junction of Yellowleaf and Red Pine Roads. Water is pumped uphill filling two storage tanks (10k gallons ea.) located on US Forest Service land just West of the apex of Lodgepole Road. These tanks (System 1) serve connections on Lodgepole, Longleaf, Red Pine, Yellowleaf, Bitterroot, all of S Blackjack and Mugo Pine Roads.

Water Testing

In the past 12 months, we have had numerous water sample tests, which include the monthly coliform tests. All were passed as “no exceedance” with one exception, the sample from 12/4/17. As a result, I sent in 5 additional samples all taken from the same source (North Well Field). All 5 samples passed. See image below.



Washington State Department of

Health Office of Drinking Water

Division of Environmental Health

Individual System View - PINE FOREST WATER SYSTEM - Water System Id - 67393

Help

Compliance Actions

Operating Permits

Operators

Reports

Water Use Efficiency

General Information

Source Information

Samples

Exceedances

Water Quality Monitoring Schedule

Source	DOE Source	Collect Date ▼	Test Panel	Analyte Group	Sample Number	Lab Number	Exceedances
Dist		6/4/2018	COLI_AP	MICRO	00616	093	No
Dist		5/7/2018	COLI_AP	MICRO	00455	093	No
Dist		4/2/2018	COLI_AP	MICRO	00295	093	No
Dist		3/5/2018	COLI_AP	MICRO	00223	093	No
Dist		2/5/2018	COLI_AP	MICRO	00136	093	No
Dist		1/10/2018	COLI_AP	MICRO	00047	093	No
Dist		12/6/2017	COLI_AP	MICRO	01553	093	No
Dist		12/6/2017	COLI_AP	MICRO	01554	093	No
02		12/6/2017	COLI_AP	MICRO	01550	093	No
04		12/6/2017	COLI_AP	MICRO	01551	093	No
Dist		12/6/2017	COLI_AP	MICRO	01552	093	No
Dist		12/4/2017	COLI_AP	MICRO	01533	093	Yes
Dist		11/6/2017	COLI_AP	MICRO	01431	093	No
Dist		10/5/2017	COLI_AP	MICRO	01317	093	No
Dist		9/5/2017	COLI_AP	MICRO	01160	093	No
Dist		8/7/2017	COLI_AP	MICRO	01013	093	No
Dist		7/3/2017	COLI_AP	MICRO	00801	093	No